

## 2012 INTERNATIONAL FIRE CODE

**507.5.2 Inspection, testing and maintenance.** Fire hydrant systems shall be subject to periodic tests as required by the *fire code official*. Fire hydrant systems shall be maintained in an operative condition at all times and shall be repaired where defective. Additions, repairs, *alterations* and servicing shall comply with *approved* standards.

**507.5.3 Private fire service mains and water tanks.** Private fire service mains and water tanks shall be periodically inspected, tested and maintained in accordance with NFPA 25 at the following intervals:

1. Private fire hydrants (all types): Inspection annually and after each operation; flow test and maintenance annually.
2. Fire service main piping: Inspection of exposed, annually; flow test every 5 years.
3. Fire service main piping strainers: Inspection and maintenance after each use.

**507.2.1 Private fire service mains.** Private fire service mains and appurtenances shall be installed in accordance with NFPA 24.

**507.2.2 Water tanks.** Water tanks for private fire protection shall be installed in accordance with NFPA 22.

**507.3 Fire flow.** Fire flow requirements for buildings or portions of buildings and facilities shall be determined by an *approved* method.

**507.4 Water supply test.** The *fire code official* shall be notified prior to the water supply test. Water supply tests shall be witnessed by the *fire code official* or *approved* documentation of the test shall be provided to the *fire code official* prior to final approval of the water supply system.

**507.5 Fire hydrant systems.** Fire hydrant systems shall comply with Sections 507.5.1 through 507.5.6.

**507.5.1 Where required.** Where a portion of the facility or building hereafter constructed or moved into or within the jurisdiction is more than 400 feet (122 m) from a hydrant on a fire apparatus access road, as measured by an *approved* route around the exterior of the facility or building, on-site fire hydrants and mains shall be provided where required by the *fire code official*.



FLOW TESTING SERVICES

# Flow Test Summary

EJ Flow Tests Project Name: Province Parcel 3  
 EJ Flow Tests Project No.: 16034  
 Project Address: West Smith Enke Road & Province Parkway, Maricopa, AZ 85138  
 Date of Flow Test: February 10, 2016  
 Time of Flow Test: 10:45 AM  
 Data is Current and Reliable Until: August 10, 2016

### Raw Test Data:

Static Pressure: 71.0 psi  
 (measured in pounds per square inch)

Residual Pressure: 66.0 psi  
 (measured in pounds per square inch)

Pitot Pressure: 30.0 psi  
 (measured in pounds per square inch)

Number of Outlets Flowed: 2

Fire Hydrant Orifice Diameter: 2.5 inches  
 (measured in inches)

Coefficient of Discharge: 0.9  
 (0.9 smooth/round outlet, 0.8 square/sharp outlet,  
 0.7 square/raised outlet)

Flowing GPM: 1,839  
 (measured in gallons per minute)

GPM at 20 PSI: 6,444

### Data with minimum safety factor of: 10% :

Static Pressure: 63.9 psi  
 (measured in pounds per square inch)

Residual Pressure: 58.9 psi  
 (measured in pounds per square inch)

Main Size: Not provided  
 (measured in inches)

Approximate Distance Between Hydrants: 365 ft  
 (measured in feet)

Approx. Static/Residual Hydrant Elevation: 1,168 ft  
 (measured above sea level)

Approx. Flow Hydrant Elevation: 1,166 ft  
 (measured above sea level)


Flowing GPM: 1,839  
 (measured in gallons per minute)

GPM at 20 PSI: 5,943

### Conducted by/Witnessed by/City Forces Contacted:

Conducted by: Austin Gourley & Eder Cueva (EJ Flow Tests) 602.999.7637  
 Witnessed by: Eddie R. (COM FM) 520.251.0024, Joe B. (GW) 480.560.5702 & Ken O. (Land Mgmt.) 480.213.5426  
 City Forces Contacted: City of Maricopa Fire Department (520.251.0024) & Global Water (480.560.5702)

### Flow Test Vicinity Map (No Scale)



E J Flow Tests, LLC

21505 North 78th Ave. • Suite 125 • Peoria, Arizona 85382 • 602.999.7637 • [www.ejflowtests.com](http://www.ejflowtests.com)  
 John L. Echeverri • NICET Level IV 078493 SME • C-16 FP Contractor ROC 271705 AZ • NFPA CFPS 1915

Image Courtesy of Google Earth

FLOW TEST SUMMARY REPORT

LOCATION: Culvers Maricopa  
24030 N John Wayne Parkway

DATE: 09-07-16  
TIME: 8:50

Static Hydrant Number:	1	Flowing Hydrant Number:	2
Elevation:	1	Elevation:	1
Dist. Between Hydrants:	200		
Diameter of Main:	8		
Outlet Diameter:	4.00 in	Number flowing: 1	Coeff.: 0.90
Static pressure:	61.00 psi	Residual pressure:	58.00 psi
Pitot Reading:	18.00 psi	Flow:	1823.0 gpm
Flow at 20 psi:	7492.5 gpm		





A1 N Roosevelt/Hathaway Ave  
A2- N Roosevelt/L exington Ave  
A3- N Taft/Hathaway Ave  
A4-N Taft/L exington Ave  
A5- N Wilson/L exington Ave  
A6- N Wilson/Hathaway Ave  
A7- W Madison/Wilson Ave  
A8-45268 W Garvey  
B1-Hathaway/Condrey Ave  
B2-SR347/Hathaway Ave  
B3- NW Corner Hathaway/SR347  
B4-NE Hathaway Ave/SR347  
B5-20054 N SR347  
B6-19864 N SR347  
B7-19766 N SR347  
B8-44624 W Garvey Ave  
B9-19595 N SR347  
B10-44801 W Honeycutt Rd  
B11-19754 N Condrey  
B12-19852 N Justin Ave  
C1-44554 W Burkett  
C2-44405 W Honeycutt Rd  
C3-N Plainview/W Marcopa Ave  
C4-Pershing/Burkett St  
C5-Arizona/Burkett Ave  
C6-Plainview SWW CG Hwy  
C7-44301 W CG/Marcopa Hwy  
C8-Pershing/W CG Hwy  
C9-W CG-Marcopa Hwy/S Side  
C10-W CG-Marcopa Hwy/S Side  
C11-W CG-Marcopa Hwy/S Side  
D1 19347 N SR347  
D2-45012 W Honeycutt Ave  
D3-45012 W Honeycutt Ave  
D4-44953 W Fred Cole Ln  
D5-Alley-45077 W Fred Cole Ln  
D6-19100 N Taft Ave  
D7 19200 N Taft Ave  
D8-19428 N Taft Ave  
D9-45022 W Edwards Cir  
D10-44945 W Edwards Cir  
D11-W McDavid/Hamilton Rd  
D12-46250 W McDavid Rd  
D13-46170 W McDavid Rd


7 Ranches Domestic Water Improvement District  
 Fire Hydrant Locations

THE N1/2 OF SEC. 25, T.4S., R.3E., G.&S.R.M.

- S1-Honeycutt Rd/Santa Cruz Wash  
(See Insert)
- S2-Honeycutt Rd/Porter Rd - Not easily accessible
- S4-Whisker Rd/S of Honeycutt Rd
- S5-Whisker Rd/Blazen Trail
- S6-Gunsmoke Rd/Magnolia Rd
- S7-Gunsmoke Rd/Blazen Trail
- S8-Honeycutt Rd/Cinder Rd
- S9-Cinder Rd/Cowpath Rd



Papago Butte DWID  
 PO Box 630  
 Maricopa, AZ 85139



19755 N. John Wayne Pkwy  
 Maricopa, Arizona 85139 Suite #100

Phone: (520) 251-1896  
 Emergency: (520) 251-1896  
 Fax: (520) 568-2185  
 Office: (520) 568-2339  
 gilbert.mdwid@hotmail.com

MARICOPA DOMESTIC WATER



IMPROVEMENT DISTRICT  
**Gilbert Sanchez**  
 Field Operations Manager

Maricopa - Seven Ranches - Papago Butte - Valle Escondido - New Saddleback Vista

GRAPHIC SCALE



( IN FEET )  
 1 inch = 800 ft


EXISTING WELL NO. 6

KEY MAP

(53) ROUTE ←


FND. B.C. IN H.H.  
NW COR. SEC. 21, T6S, R3E

### CLAYTON ROAD



MARICOPA ROAD-SR 347

LOPEZ RD



MEADOW VIEW ROAD

(29) Route 1

FND. B.C. IN H.H.  
SW COR. SEC. 21, T6S, R3E

Valle Escondido DWID  
PO Box 370  
Stanfield, AZ 85172

KEY MAP  
GRAPHIC SCALE






# Program Elements

1. Review System Maps and Hydraulic Model
2. Develop Optimized Flushing Program
3. Develop Field Crew Mappbooks
4. Pilot Test Worse Case Areas
5. Develop Implementation Program

# 1. Developed Map of System for UDF Program

Not the Entire System

Worked with O&M Staff to Verify Locations for Hydrants, Valves, and Blow-offs




1.

# Developed Seasonal Diurnal Curves

Normal Flow Paths and Direction of Water Movement in System Under Typical Seasonal Demands

Puts the "Uni" in Unidirectional flushing



Fall Diurnal

Summer Diurnal


Spring Diurnal

2.

# Optimized Program

## 1. Divide System into Sectors


- Sequenced to moving water from clean to dirty areas
- Configured for a minimum velocity of 6 feet per second
- Configured to maintain minimum pressure for basic service and fire flows (30 psi)
- Loops sized for completion by flushing crew in 1 day



# Optimized Program

## 2. Divide Sectors into Loops

- Sized for completion by flushing crew in 1 day
- Assures valves don't stay closed for extended periods
- Alphabetically sequence assures clean water moves into dirty areas (and not vice versa)





4.

## Pilot Testing

Worst Case Loops

Assess extent of any  
needed repairs

Best Case Loops

Road tests Mapbook  
procedures with field  
staff

Lesson Learned: Field Reconnaissance  
(Hydrant, Valves and Blow-offs) and  
include time to exercise valves

5.

# Implementation

## Safety

Accident Prevention,  
Emergency Response,  
Traffic Control, First Aid

## Response Plans

Predict and Plan: WQ  
Complaints, Ruptures,  
Stuck Valves, etc.

## Public

Raise Need Awareness,  
Give Notice, Stick to  
Schedule



5.

# Implementation

Pre-Flushing  
Site Visit

Mark Hydrants, Clean  
Valve Boxes, Exercise  
Valves, Identify  
Potential Problems